


GENERAL NOTES

ALL WORK SHALL CONFORM TO THE APPLICABLE SECTIONS OF THE SPECIFICATIONS ENTITLED "STANDARD SPECIFICATIONS, STATE OF CALIFORNIA, BUSINESS AND TRANSPORTATION AGENCY, DEPARTMENT OF TRANSPORTATION" AND THE NATIONAL ELECTRICAL CODE.

LUMINAIRE SHALL BE COBRA HEAD TYPE, 120V HIGH PRESSURE SODIUM-VAPOR WITH TYPE IV QUICK ACTING PHOTOELECTRIC CELL AND HAVE A HIGH POWER FACTOR REACTOR BALLAST. LENS SHALL BE POLYCARBONATE PLASTIC. BULB SHALL BE 150 WATT OR 70 WATT.

ALL STREET LIGHTS SHALL BE NUMBERED. NUMERICAL SEQUENCE TO BE OBTAINED FROM P.G.&E. NUMBERS TO BE 1 1/2" HIGH AND INSTALLED NINE FEET ABOVE FINISHED GRADE.



BASE DETAIL